



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Station Feeder Road, P.O & P.S Silihuri, District: Darjeeling, Pin - 734006

Date : 14-11-2024

Memo No.: FSR/211862406300005013

From :
Divisional Fire Officer
Darjeeling Division (Member Convenor)
West Bengal Fire & Emergency Services

To :
Techno India Project Pvt Ltd. (Director. Sri Satyam Roy Chowdhury)
MOUZA- SUKHANDIGHI, J.L. NO-90, PLOT NO- 124,144,143(L.R.),KH NO- 829,830,1069(LR),P.O.-
NARAYANPUR, P.S. & DIST-MALDA

Sub: Fire Safety final NOC of the construction of 7 blocks G+3 storied Admin block ,3no G+3 storied Academic block, G+3 storied Boys hostel block, G+3 storied Girls Hostel block G+3 storied Recreation block, under group of educational in the name of Techno India Project Pvt Ltd. (Director. Sri Satyam Roy Chowdhury), at the Premises no MOUZA- SUKHANDIGHI, J.L. NO-90, PLOT NO- 124,144,145(L.R.),KH NO- 829,830,1069(LR),P.O.-NARAYANPUR, P.S. & DIST-MALDA 732128

This is in reference to your AIN 211862406300005013 dated 21-Aug-2024 regarding Fire Safety. No objection of the construction of 7 blocks G+3 storied Admin block ,3no G+3 storied Academic block, G+3 storied Boys hostel block, G+3 storied Girls Hostel block G+3 storied Recreation block, under group of educational in the name of Techno India Project Pvt Ltd. (Director. Sri Satyam Roy Chowdhury), at the Premises no MOUZA- SUKHANDIGHI, J.L. NO-90, PLOT NO- 124,144,145(L.R.),KH NO- 829,830,1069(LR),P.O.-NARAYANPUR, P.S. & DIST-MALDA: 732128

The performance of the Fire Fighting system as incorporated in the building were tested at a random and found satisfactory working condition. In view of the above this office is releasing the Final NOC for occupancy of the aforesaid building.

However, to up-keep the Fire Safety Measure of the aforesaid buildings the following safety measures need to be incorporated maintained.



MANAGER
TECHNO INDIA GROUP WORLD SCHOOL
MALDA

Principal
25/11/24
PRINCIPAL
TECHNO INDIA GROUP WORLD SCHOOL
MALDA

commendation:


1. Regular checking, testing and maintenance of fire safety systems/installations are must.
2. Good housekeeping to be maintained
3. Regular checking and maintenance of electrical wiring and installation by the licensed Electricians.
4. Regular mock fire drill and evacuation drill should be conducted by the participation of all and for this purpose a special crew should be formed.
5. Certificate shall have to be obtained from this Office on routine basis about the satisfactory performances off all the fire and fire safety installations falling which the fire Safety Certificate shall be revoked as per rule 18 of the W.B. Fire Services (Fire Prevention & Fire Safety) Rules 2003.
6. Fire License shall be obtained from this department separately which is attracts section 12 of FS Act.
7. This certificate needs to be renewed after three yr. subject to ensure all safety measures should be in working condition at all time.
8. Occupancy of the building shall not be allowed to change without the concurrence of the department and floor area height etc. shall not permissible to enhance without the concurrence of this department. No addition or alteration should be allowed without the prior approval of this department.
9. Separate entrance and exit to be provided.
10. Staircases required to be provided within travel distance and shall be free from any obstructin.
11. ~~11. B. of fire safety NOTIFICATION 1830 F.S. / D.150.06/2023 D.14.11.24.~~

Memo No.. FSR/211862406300005013

Valid Upto : 14-Nov-2027


MANAGER
TECHNO INDIA GROUP WORLD SCHOOL
MALDA




Signature Not Verified

PRINCIPAL
TECHNO INDIA GROUP WORLD SCHOOL
MALDA
Digitally Signed
Name: DEVANLECHA
Date: 14-Nov-2024 13:54:01
Reason: D-Sign
Location: F-Dist 21

Divisional Fire Officer

West Bengal Fire & Emergency Services